

Village of Ruidoso
313 Cree Meadows Dr.
Ruidoso, NM 88345

DATE: March 10, 2017

IFB# 2017-012B Well H-1497-POD4 (Green Well) Pump Repair and Well Rehabilitation

The following **ADDENDUM #1** shall be incorporated into the Bid Documents for the above referenced project.

Question #1-Will a rig rate be allowed or apply if the pump removal takes more time than the contractor estimates? **Answer: No. Contractor shall perform the work on a lump sum basis.**

Question #2-How is electrical cable attached to the drop-pipe? **Answer: Unknown.**

Question #3-Can contractor perform pump and motor evaluation and repair? **Answer: No. Pump and motor shall be sent to Gieon as specified.**

Question #4- Where can developed water be discharged after neutralization? **Answer: Water can be discharged to Village property but must not flow into Eagle Creek.**

Question #5- If developed water is neutralized and stored in tanks where can it be hauled for disposal? **Answer: Unknown. Contractor shall make arrangements to have fluid hauled off if that is their proposed approach.**

Question #6- Can barricades around the well head be moved? **Answer: Barricades can be moved from the well head during work, but must be put back in place to protect the well head whenever equipment is not in place, and at the end of the project.**

The following clarification/adjustments shall be incorporated in the bid documents and included in your bid. Please enter the latest addendum number on the bid page where requested.

Please sign and return by E-Mail (See Below)

Company

Signature and Date of receipt of Fax

Phone: 575/257-2721 FAX: 575/257-2628
Email: Billyrandolph@ruidoso-nm.gov
Sidneythomas@ruidoso-nm.gov