

October 20, 2017

To: All Holders of Contract Documents

Ref: Addendum #1  
Camelot Liftstation Rehabilitation Phase 2  
R308202.01

Addendum #1 shall be incorporated into the Contract Documents for the above referenced project. The Addendum includes information for bidders including notes from the Pre-Bid Meeting and questions received, and updated electrical drawings.

Notes from Pre-Bid Meeting:

- Rehab will be on Liftstations 4 & 5,
- Liftstation 4 & 5 are currently pumped twice a week producing an approximate 1,800 gallons a week per liftstation,
- Who's responsible for the liftstations during construction,
  - Once Contractor has mobilized on-site maintenance of liftstation 4 & 5 will be the responsibility of the Contractor including but not limited to by-pass pumping or other means of liquid waste management,
- What electrical components will be provided by the Village of Ruidoso via JCH? Are the electrical disconnects provided by the Village,
  - The electrical components listed in the provided JCH submittal will be the only electrical components provided by the Village. Contractor will be responsible for all other components including, but not limited to, the electrical disconnects and materials and labor to pull the electrical service across the existing roadway, if required.
- Will there be inserts provided by JCH for the bottom trough and bench in the bottom of the liftstations?
  - No, the contractor will be responsible to install a concrete trough and bench to direct wastewater to the submersible pumps.
- Is the DIP material for replacement of pipe in the wetwell included in the JCH proposal?
  - Please refer to the JCH submittal(s) for material provided. DIP for replacement of the piping of the wetwell will be the responsibility of the Contractor to provide and install.
- Do the provided electrical components (as provided by JCH) include the stand for the electrical panels?
  - No, all material not provided for in the JCH submittal will be the responsibility of the Contractor to provide including the stand for the electrical panels.

**End of Pre-Bid Meeting – adjourned at 1:20 PM – meeting in the field for walk through**

- **No additional questions were received by the question deadline of 10/19/2017 @ 5:00 PM.**

ALL OTHER PROVISIONS OF THE CONTRACT DOCUMENT SHALL REMAIN UNCHANGED. THIS ADDENDUM IS HEREBY MADE A PART OF THE CONTRACT DOCUMENTS TO THE SAME EXTENT AS THOSE PROVISIONS CONTAINED IN THE ORIGINAL DOCUMENTS AND ALL ITEMS LISTING THEREOF. EACH BIDDER SHALL ACKNOWLEDGE RECEIPT OF ADDENDUM NUMBER ONE (1) ON THE BID PROPOSAL FORM IN THE SPACE PROVIDED.

**HUITT-ZOLLARS, INC.**



Raymond D. De La Vega  
NMPE License #: 21078